

## Photometric Measurement Report

Generated by Radiant Vision Systems Light Measurement Platform

<b>Luminaire Model</b>	L DL2402030		
<b>Led &amp; Driver Type</b>	SAMSUNG	26D2	& TCI PROFESSIONALE 42
<b>Luminaire Type</b>	DOWNLIGHT		
<b>Luminaire Family</b>	L-UGR		
<b>Holder</b>	BAHO HOLDER		
<b>Reflector / Lens Degree</b>	72		
<b>Brand</b>	LAMP 83		
<b>Date of issue</b>	07.05.2018		

### Test Standards

EN 13032-1:2012 and EN 13032-4:2013 Light and Lighting. Measurement and presentation of photometric data of lamps and luminaires

IESNA LM-79-08 Approved Method: Electrical and Photometric Measurements of SSL Products(Type-C)

### Test and Test Method

The photometric measurements listed in this report are performed by a Radiant Vision Systems PM-NFMS™ near field goniometer system. The NFMS system performs brightness and color measurements as a function of viewing angle. It provides accurate near-field luminance distribution data and generates far field distribution data.

### Test Equipment

Name	Serial / Version
The PM-NFMS™ system consists of a PM-Series™ Imaging Colorimeter IC-PMI2	SN# 79046501
NFMS 800 two-axis goniometer	SN# 641502001
SP-1000 spectrometer	SN# 3017942276
PM-NFMS™ software	Version 4.9.9
ProSource™ Software	Version 10.2.2

The measurement data is preserved as a set of images Radiant Source Model™(RSMX). The ProSource™ Software (Version 10.2.2) was been used to convert the RSMX to a ray set(LTD file)

### Laboratory Environment and Conditions

The measurement was done in the photometric laboratory of Lamp83 (Istanbul). It is a climate controlled dark room. Also a AC/DC power stabilisation unit is used(Pyramid Plus PPS310,8KW,10kVA,SN# 073010T0066).

<b>Temperature:</b>	25°C	(± 1 °C)
<b>Moisture:</b>	60%	(± 10 %)

The luminaire was thermally stabilized for **at least 45 minutes** on the goniometer. The end of the stabilization period has been reached if in the last 10 minutes the luminance output has not changed by more than ± 0.5%.

### Equipment Specifications

Precision: 0.25° (NFMS Goniometer)

Luminance (Y): ± 3% (Imaging Colotimeter IC-PMI2)

Color Accuracy: ± 0.002 Illuminant A type sourc (Spectrometer SP-1000)

<b>Tested By:</b>
Gökhan AKSEL Test Technician

<b>Reviewed By:</b>
Anıl TOKER Physics Engineer

<b>Approved By:</b>
Erdoğan EMREM R&D Manager

LAMP83 Aydınlatma San. Ve Tic. A.S

Dudullu Organize Sanayi Bölgesi 2. Cadde No:22 PK: 34775 Ümraniye - İstanbul

## Photometric Measurement Report

Generated by Radiant Vision Systems Light Measurement Platform




Luminaire Spectroradiometric Results	
Luminous Flux (lm)	2735
CCT (K)	3,018
Cx	0.4389
Cy	0.4104
CRI	85
Luminous Efficacy (lm/W)	116.98
Angle (°)	72.0

Luminaire Electric Specifications	
Voltage (VAC)	221.4
Current (A)	0.11
Power (W)	23.37984
Power Factor	0.96
LED Voltage(VDC)	33.71
LED Current(mA)	603
LED Power(W)	20.32713

Measurement Preset Specifications	
External ND Filter	YES
ND Filter	ND1
F-Number	8
Exposure Time (ms)	156.5
Distance(mm)	2020

### Rendering Index

CRI	
R1	82.9
R2	91.5
R3	97.7
R4	83.0
R5	83.0
R6	89.9
R7	85.9
R8	65.0
R9	19.8
R10	80.8
R11	82.2
R12	73.2
R13	84.8
R14	99.2
CRI Ra	84.9




**Photometric Measurement Report**


Generated by Radiant Vision Systems Light Measurement Platform

**Intensity Distribution - Polar Curve**

Intensity Radar Plot (ray trace to infinity)



Luminous Intensity Distribution



**Cone Diagram**

0.5	0.71	E(0°)	8117
	0.71	E(C90) 35.4°	2222
1.0	1.42	E(C0) 35.3°	2224
	1.42	E(0°)	2029
1.5	2.13	E(C90) 35.4°	556
	2.12	E(C0) 35.3°	556
2.0	2.84	E(0°)	902
	2.83	E(C90) 35.4°	247
2.5	3.55	E(C0) 35.3°	247
	3.54	E(0°)	507
3.0	4.26	E(C90) 35.4°	139
	4.25	E(C0) 35.3°	139
		E(0°)	325
		E(C90) 35.4°	89
		E(C0) 35.3°	89
		E(0°)	225
		E(C90) 35.4°	62
		E(C0) 35.3°	62

Distance [m]                      Cone Diameter [m]                      Illuminance [lx]

— C0 - C180 (Half value angle: 70.6°)

— C90 - C270 (Half value angle: 70.8°)

## Photometric Measurement Report

Generated by Radiant Vision Systems Light Measurement Platform

### UGR Table

#### Glare Evaluation According to UGR

$\rho$ Ceiling	70	70	50	50	30	70	70	50	50	30	
$\rho$ Walls	50	30	50	30	30	50	30	50	30	30	
$\rho$ Floor	20	20	20	20	20	20	20	20	20	20	
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	20.2	21.1	20.5	21.3	21.5	20.4	21.2	20.6	21.4	21.6
	3H	20.1	20.9	20.4	21.1	21.3	20.3	21.0	20.6	21.3	21.5
	4H	20.1	20.8	20.4	21.0	21.3	20.2	20.9	20.5	21.2	21.4
	6H	20.0	20.6	20.3	20.9	21.2	20.2	20.8	20.5	21.1	21.4
	8H	20.0	20.6	20.3	20.9	21.2	20.2	20.8	20.5	21.1	21.4
4H	12H	19.9	20.5	20.3	20.8	21.2	20.1	20.7	20.5	21.0	21.3
	2H	20.1	20.8	20.4	21.0	21.3	20.2	20.9	20.5	21.2	21.4
	3H	20.0	20.6	20.3	20.9	21.2	20.1	20.7	20.5	21.0	21.3
	4H	19.9	20.4	20.3	20.8	21.1	20.1	20.6	20.5	20.9	21.3
	6H	19.9	20.3	20.3	20.7	21.0	20.1	20.5	20.5	20.8	21.2
8H	8H	19.8	20.2	20.3	20.6	21.0	20.0	20.4	20.5	20.8	21.2
	12H	19.8	20.2	20.3	20.6	21.0	20.0	20.4	20.5	20.8	21.2
	4H	19.8	20.2	20.2	20.6	21.0	20.0	20.4	20.4	20.8	21.2
	6H	19.8	20.1	20.2	20.5	20.9	20.0	20.3	20.4	20.7	21.1
	8H	19.7	20.0	20.2	20.4	20.9	20.0	20.2	20.4	20.7	21.1
12H	12H	19.7	19.9	20.2	20.4	20.9	20.0	20.2	20.4	20.6	21.1
	4H	19.8	20.1	20.2	20.5	21.0	20.0	20.3	20.4	20.7	21.1
	6H	19.7	20.0	20.2	20.4	20.9	19.9	20.2	20.4	20.6	21.1
	8H	19.7	19.9	20.2	20.4	20.9	19.9	20.1	20.4	20.6	21.1
	12H	19.7	19.9	20.2	20.4	20.9	19.9	20.1	20.4	20.6	21.1
Variation of the observerposition for the luminaire distance S											
S = 1.0H	+3.0 / -7.3					+2.8 / -5.7					
S = 1.5H	+5.3 / -10.1					+5.1 / -8.2					
S = 2.0H	+7.3 / -11.2					+7.1 / -9.4					
Standard table	BK00					BK00					
Correction summand	1.7					1.8					
Corrected glare indices referring to 2736lm total luminous flux											

### Sample Pictures